



September 21, 2012

Mr. Bryan Hughes  
President  
Tufdek/Tuff Industries Inc.  
9570 Bottom Woodlake Rd.  
Lake Country, BC V4V 1S7  
Canada

Dear Mr. Hughes:

Congratulations! The product listed below submitted for Phase 2 Testing in September 2009 is now recertified as providing "High-Traction". Your new certification will continue through September 21, 2015.

**NFSI Certified Products:**

Tufdek

During the original testing protocol your product was installed in a commercial facility for a period of 30 days, and tested under NFSI test method 101-A (now titled ANSI/NFSI B101.1-2009). An on-site examination revealed Static Coefficient of Friction (SCOF) values greater than a 0.6 and therefore passed our Phase 2 level of certification.

An electronic version of the NFSI Certified logo may be obtained to which you are granted permission to attach to the label, sales literature, website, etc.

Again, congratulations and thank you for recertifying your product with the NFSI.

Sincerely,

Russell J. Kendzior  
President

RJK/lc